



CERTIFICATE OF REGISTRATION

This is to certify that the Construction product known as BOOSTR HYBRID / BOOSTR HYBRID Roof (breather membrane with built in thermal performance), manufactured by

ACTIS SA

Avenue de Catalogne 11300 Limoux France

and distributed in the UK by:

ACTIS INSULATION Ltd

Unit 2a Cornbrash Park, **Bumpers Way Bumpers Farm Industrial Estate** Chippenham Wiltshire **SN14 6RA**

Has been assessed in accordance with the BM TRADA Q-Mark Scheme for Construction Products. The product meets the requirements of the above mentioned Scheme, EN 13859-1 and EN 13859-2 and is intended for use in Roofs and Walls and Floors. It has a water vapour transmission resistance of Z=0.55 MNs/g, a water tightness rating of Class W1. BOOSTR HYBRID and BOOSTR HYBRID Roof also provides complementary thermal insulation performance, although it is outside of the scope of BS EN 13859-1-2. Their insulation properties have been additionally tested according to EN 16012 with a core R-value declared at 1.35m2K/W, an emissivity declared at 0.05 for its inner side and 0.31 or 0.9 for its outer side and an R-value with 2 adjacent air gaps of 20 mm declared at 2.40m2K/W. BOOST'R HYBRID and BOOSTR HYBRID Roof is registered within the BM TRADA Q-Mark Scheme for Construction Products.

> Steve Roberts **Product Certification Operations Manager** For and on behalf of BM TRADA

Certificate number:

CPS-014

Date of Initial Certification:

4 March 2013

Date of Last Issue:

1 February 2022

Date of Expiry:

3 March 2025

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire,

Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA, UK